



**UNIVERSITY OF NAIROBI**  
**Director Supply Chain Management Services**

Email: [directorsupplychain@uonbi.ac.ke](mailto:directorsupplychain@uonbi.ac.ke)  
Website: [www.uonbi.ac.ke](http://www.uonbi.ac.ke)

Tel: +254-020-4910000  
DL: +254-020-4913026  
P.O Box 30197 - 00100 - GPO  
Nairobi, Kenya

**ADDENDUM FOR TENDER NO: UON/ONT/13/2021-2022 FOR PROPOSED INSTALLATION OF STAGE LIGHTING AND ASSOCIATED WORKS IN TAIFA HALL AT THE UNIVERSITY OF NAIROBI**

Further to the Tender Document issued by the University on 2<sup>nd</sup> June 2022; the following changes have been made to the Tender Document:

**BILL 2**

1. Item 2.04 which is the description of the LV Board has been adjusted as in the attached **Addendum A.**

**BILL 4**

2. Bill 4 on page 73 concerning the Centralized Voltage Stabilizer has been **removed**. The Centralized Voltage Stabilizer shall therefore **NOT** be quoted for in the **Main Summary Page**. However, there should be a provision/ allowance for installation of the centralized voltage stabilizer in the future.

**BILL 5**

3. Item 5.01: The cable carrying power from the Main board in Gandhi Wing to the Taifa Hall sub-board is **150 mm sq.** 4 Core PVC/XLPE/SWA/PVC and not **300 mm sq.** 4 Core PVC/XLPE/SWA/PVC as indicated in initial document. The length of the cable is also **150m** and not **40m**.
4. Item 5.02: Cable lugs should be for **150mm sq.** and not **300mm sq.**
5. Item 5.03: Cable glands should be for **150mm sq.** and not **300mm sq.**

The revised Bill 5 is hereby attached as Addendum B

DICKSON LUGONZO, MCIPS, MKISM

DATE

7/6/22

DIRECTOR, SUPPLY CHAIN MANAGEMENT SERVICES